

Zhejiang Tengen Electrics Co., Ltd.
Li Li
-
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P.R. China

Date : 02.03.2017
Our ref. : ZHB ZC10
Your ref.: L.L.

Ref : R TÜV-Mark Approval

Type of Equipment : Low-voltage Fuse
Model Designation : See Certificate
Certificate No. : R 50359011 0001
Report No. : 50056250 001

Dear Li Li,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.


Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body



James Li

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50359011

Blatt *Page*
0001

Ihr Zeichen *Client Reference*
L.L.

Unser Zeichen *Our Reference*
ZC10-ZHB-50056250 001

Ausstellungsdatum *Date of Issue*
02.03.2017 (day/mo/yr)

Genehmigungsinhaber *License Holder*
Zhejiang Tengen Electrics
Co., Ltd.
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P.R. China

Fertigungsstätte *Manufacturing Plant*
Zhejiang Tengen Electrics
Co., Ltd.
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P.R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60269-1:2007+A1+A2
HD 60269-2:2013

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Fuse (Low-voltage Fuse)

Type Designation : 1) RT16-00 2) RT16Z-00 (TENGEN)

Fuse-link

Rated Voltage and

Rated Breaking Capacity: 1) 2) AC 500V 120kA
AC 690V 50kA

2) DC 250V 100kA

Rated Current : 2A, 4A, 6A, 10A, 16A, 20A, 25A,
32A, 40A, 50A, 63A, 80A, 100A,
125A, 160A

Breaking Range : gG

Rated Power Dissipation: ≤12W

Size : 00

Continued on page 0002

6

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle

James Li

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50359011

Blatt *Page*
0002

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum <i>Date of Issue</i>
L.L.	ZC10-ZHB-50056250 001	02.03.2017 (day/mo/yr)

Genehmigungsinhaber *License Holder*
Zhejiang Tengen Electrics
Co., Ltd.
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P.R. China

Fertigungsstätte *Manufacturing Plant*
Zhejiang Tengen Electrics
Co., Ltd.
Tengen Industry Zone, Liushi,
Yueqing, Zhejiang 325604
P.R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60269-1:2007+A1+A2
HD 60269-2:2013

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

Fuse (Low-voltage Fuse)

Continuation from page 0001

Fuse-base
Rated Voltage : 1) 2) AC 500V, 690V
2) DC 250V
Rated Current : 160A

The labelling requirements acc. to EU Directive 2001/95
have to be observed for distribution within the EEA.

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



James Li