





TEST REPORT EN 60947-2 Low-voltage switchgear and controlgear - Part 2: Circuit-breakers	
Report Number.....:	(2023)FQIIDQCE-0340
Date of issue.....:	2023-10-25
Total number of pages	27
Name of Testing Laboratory preparing the Report.....:	Fujian Inspection and Research Institute for Product Quality (FQII)
Applicant's name	Zhejiang Tengen Electric Co., Ltd.
Address	Sulv Industrial Area, Lishi Town, Yueqing City, Zhejiang Province, P.R.China
Test specification: Standard EN 60947-2:2017, EN 60947-2:2017/A1:2020 Non-standard test method N/A	
Test Report Form No.:	IEC60947_2K
Test Report Form(s) Originator..:	DEKRA Certification B.V.
Master TRF	Dated 2023-09-14
Copyright © 2023 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved. <small>This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.</small> This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.	
General disclaimer: The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.	

Test item description	MCCB
Trade Mark(s).....	TENGEN
Manufacturer	Zhejiang Tengen Electric Co.,Ltd. / Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China
Model/Type reference	TGM3-800L, TGM3-800M, TGM3-800H
Ratings.....	Uimp:8kV;Ui: 800V; Ue:AC400V/690V; In:400A,500A,600A,630A,700A,800A; Type of over-current release: Thermo-magnetic,Electro- magnetic; Type L :400V:Ics:35kA,Icu:50kA;690V:Ics:10kA,Icu:15kA; Type M:400V:Ics:65kA,Icu:65kA;690V:Ics:20kA,Icu:20kA; Type H:400V:Ics:65kA,Icu:85kA;690V:Ics:20kA,Icu:30kA; Selectivity category: A; 3P,3P+N(Type A:3 protected poles with an uninterrupted neutral pole;Type D:3 protected poles with a protected uninterrupted neutral pole);4P(Type B:3 protected poles with a switched neutral pole;Type C:4 protected poles); 3P, 4P: suitable for isolation; 3P+N:Not suitable for isolation; Matching auxiliary contact:FC38-400, 1NO1NC,2NO2NC,4NO4NC,Ui:690V,Ith:6A, AC-15:(380/400)V/1A,DC-13:(220/230)V/0.15A; Electronic annex in Appendix N: Undervoltage release:QT38-400, Us:AC(220/230)V,AC(380/400)V; Motor-operator:CD2-800,Us:AC(220/230)V,AC(380/400)V

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
<input checked="" type="checkbox"/>	CB Testing Laboratory:	Fujian Inspection and Research Institute for Product Quality(FQII)
Testing location/ address		No.6,Shuangfeng Road, Hongshan,Gulou District, Fuzhou,Fujian 350002 China & No.101,Baozhen Road,Mawei, Mawei District,Fuzhou,Fujian 350015 China
Tested by (name, function, signature):		Yang Jilin (Engineer) 
Approved by (name, function, signature) :		Wei Yunming (Chief Engineer) 
Testing procedure: CTF Stage 1:		
Testing location/ address		
Tested by (name, function, signature) :		
Approved by (name, function, signature) :		
Testing procedure: CTF Stage 2:		
Testing location/ address		
Tested by (name + signature)		
Witnessed by (name, function, signature) :		
Approved by (name, function, signature) :		
Testing procedure: CTF Stage 3:		
Testing procedure: CTF Stage 4:		
Testing location/ address		
Tested by (name, function, signature) :		
Witnessed by (name, function, signature) :		
Approved by (name, function, signature) :		
Supervised by (name, function, signature)		